



CI-0702

TAB 7: TECHNICAL DISCIPLINES

Mechanical

CUSTODIAN SINKS

Janitor sinks to be terrazzo, floor mounted.

WASHBASINS

- > Multi use public washrooms to have individual semi-countertop basins with one barrier free basin. Faucets to be two-handle centreset type for the barrier free basin.
- > Universal washrooms to have a barrier free semi-countertop mounted basin with a two-handle centreset faucet.
- > Staff washroom basin to be countertop type with a two handle centreset faucet. There shall be a storage cabinet below.
- > Shop or maintenance facility washrooms to have a trough-type multi-station sink or circular wash basin. Faucets can have foot control, infrared control, or push button control.

WATER CLOSETS

- > Water closets in public washrooms shall be wall hung, with carrier elongated siphon jet flush action bowl, top spud for exposed manual flush valve with non-hold open feature. Seats shall be white, elongated, heavy duty, solid material, open front without cover.
- > Water closets in staff washrooms shall be floor mounted tank type. Seat shall be white, heavy duty, open front, solid material, oval, with cover.
- > Barrier-free (accessible) water closets shall have covers (lids) as back-rests, to code requirements.

URINALS

Urinals shall be wall hung with carrier, top spud for exposed manual flush valve with non-hold open feature and vacuum breaker, siphon jet flush action, integral flush spreader.

EYE WASH FOUNTAINS

In rail and bus maintenance facilities, eye wash fountains shall be wall recessed, stainless steel, located per Code outside battery rooms, or other areas with hazardous products. Typically found in plant facilities.

SPECIAL REQUIREMENTS

- > Septic systems and/or holding tanks for rural facilities.