



CI-0202

TAB 2: SITE INFRASTRUCTURE AND DEVELOPMENT
Station Sites

Building Entrance: At least one entrance to GO facilities shall be mobility accessible and shall be located on a level that would provide access to elevators and or ramps.

Entrances: shall be accessible to people using wheelchairs or scooters. The following features shall form part of an accessible entrance:

- > Power assisted door operators, with guards;
- > Accessible entrances shall be clearly marked with the International Symbol of Accessibility;
- > Can be easily opened with one hand;
- > Canopies or other sheltering devices where present, shall have adequate headroom; and
- > Mats shall be level with the floor and door thresholds are bevelled so they do not create a tripping hazard.



ACCESSIBLE CURBS

- > Accessible curbs (curb cuts) shall be provided where pedestrian paths intersect with vehicular roads, at barrier-free parking spaces, and wherever there is change in level along a barrier-free path of travel.
- > Directional grooves at 300 mm centres shall be provided, in accordance with OPSD 310.030.
- > Where an accessible curb is provided, the surface shall have tactile indicators on its surface that meet the following requirements:
 - have raised tactile profiles
 - have a high tonal contrast with the adjacent surface
 - are set back between 150 mm and 200 mm from the curb edge
 - extend the full width of the curb
 - have a minimum of 610 mm in depth
 - have a maximum running slope of 1:15